



NOTICE OF LEAD SERVICE LINE INVENTORY COMPLETION:

Oregon Health Authority Drinking Water Services reviewed and accepted a service line inventory for Public Water System 00952 WHEELER WATER SYSTEM, received on **10/10/2024**. The inventory showed that the water system has all non-lead service lines.

Service lines were identified using the Statistical Method approved by Oregon Health Authority. 20% of the system's service connections were randomly sampled and physically inspected for the inventory. A complete summary of findings can be found at:

[00952 Lead & Copper | Data Online | Oregon Drinking Water Services](#) (Click on Service Lines tab)

Please contact Phil Chick, Public Works Director, with any questions about this inventory or any other water quality matter.

Thank you for trusting the City of Wheeler to serve you.